

# MONITORING SURVEY RESULTS



## JOB DETAILS

Survey No 60  
 Job Name  
 Survey Date 01/12/2017  
 Survey By David Regan

## LIMITS (METRES)

Horizontal 0.0150  
 Vertical 0.0150

## SETUP ACCURACY (METRES)

Plan / Height <0.001 m

## TRIGGER VALUE COMMENTS

**Horizontal** Horizontal limits have been exceeded, see results  
**Vertical** Vertical limits have been exceeded, see results

## NOTES:

P10 Blocked due to Scaffolding | P11 Blocked due to Scaffolding | P14 Blocked due to Scaffolding | P15 Blocked due to Scaffolding | P16 Blocked due to Scaffolding | P17 Blocked due to Scaffolding | P55 Missing | P57 Missing | P48 Blocked due to refuse skip | P52A Blocked due to refuse skip | P44 Blocked due to Scaffolding | P50 Blocked due to Temporary Building | P37 Blocked due to Scaffolding | P38 Blocked due to Scaffolding | P39 Blocked due to Scaffolding | P47 Blocked due to Building Materials on roof of portacabin

SURVEYED POSITIONS					DIFFERENCES BETWEEN READINGS			
POINT ID	EASTING	NORTHING	HEIGHT	COMMENT	BASE - HORIZONTAL	BASE - VERTICAL	PREVIOUS - HORIZONTAL	PREVIOUS - VERTICAL
P01	142.048	523.540	53.084		0.0026	0.0002	0.0003	0.0006
P02	142.029	523.554	56.610		0.0024	0.0009	0.0013	0.0003
P03	142.009	523.459	59.224		0.0018	0.0000	0.0014	0.0003
P04	140.916	522.028	59.167		0.0012	0.0001	0.0019	0.0001
P05	140.861	522.005	56.677		0.0017	0.0002	0.0023	0.0003
P06	141.046	522.123	52.875		0.0020	0.0000	0.0014	0.0002
P07	139.902	520.663	52.833		0.0024	0.0007	0.0005	0.0005
P08	139.472	520.237	56.583		0.0020	0.0007	0.0004	0.0005
P09	139.843	520.632	59.177		0.0016	0.0002	0.0011	0.0002
P12	132.359	510.295	54.073		0.0025	0.0015	0.0009	0.0001
P13	129.366	506.233	53.782		0.0019	0.0017	0.0012	0.0004
P18	128.809	505.518	53.757		0.0013	0.0019	0.0004	0.0002
P19	125.772	501.178	53.398		0.0013	0.0009	0.0014	0.0006
P20	125.695	501.024	57.087		0.0006	0.0003	0.0006	0.0005
P21	125.570	500.848	58.438		0.0015	0.0001	0.0008	0.0006
P22	122.563	496.547	58.466		0.0008	0.0004	0.0006	0.0004
P23	122.569	496.553	57.604		0.0009	0.0006	0.0005	0.0003

# MONITORING SURVEY RESULTS



## JOB DETAILS

Survey No 60  
 Job Name  
 Survey Date 01/12/2017  
 Survey By David Regan

## LIMITS (METRES)

Horizontal 0.0150  
 Vertical 0.0150

## SETUP ACCURACY (METRES)

Plan / Height <0.001 m

## TRIGGER VALUE COMMENTS

**Horizontal** Horizontal limits have been exceeded, see results  
**Vertical** Vertical limits have been exceeded, see results

## NOTES:

P10 Blocked due to Scaffolding | P11 Blocked due to Scaffolding | P14 Blocked due to Scaffolding | P15 Blocked due to Scaffolding | P16 Blocked due to Scaffolding | P17 Blocked due to Scaffolding | P55 Missing | P57 Missing | P48 Blocked due to refuse skip | P52A Blocked due to refuse skip | P44 Blocked due to Scaffolding | P50 Blocked due to Temporary Building | P37 Blocked due to Scaffolding | P38 Blocked due to Scaffolding | P39 Blocked due to Scaffolding | P47 Blocked due to Building Materials on roof of portacabin

SURVEYED POSITIONS					DIFFERENCES BETWEEN READINGS			
POINT ID	EASTING	NORTHING	HEIGHT	COMMENT	BASE - HORIZONTAL	BASE - VERTICAL	PREVIOUS - HORIZONTAL	PREVIOUS - VERTICAL
P24	122.715	496.811	53.444		0.0011	0.0000	0.0010	0.0006
P25	120.278	496.543	53.280		0.0010	0.0000	0.0005	0.0009
P26	120.364	496.669	56.116		0.0009	0.0001	0.0008	0.0006
P27	120.305	496.568	57.854		0.0013	0.0002	0.0007	0.0006
P28	118.480	493.552	58.404		0.0009	0.0018	0.0011	0.0019
P29	118.428	493.460	56.413		0.0015	0.0006	0.0012	0.0010
P30	118.445	493.504	53.245		0.0006	0.0002	0.0011	0.0006
P31	116.634	490.492	53.273		0.0017	0.0009	0.0013	0.0007
P32	116.640	490.489	56.426		0.0006	0.0011	0.0010	0.0012
P33	116.646	490.493	58.396		0.0008	0.0016	0.0002	0.0011
P34	121.748	519.600	54.814		0.0096	0.0194	0.0003	0.0002
P35	129.543	514.212	54.805		0.0082	0.0137	0.0020	0.0003
P36	129.615	514.356	65.635		0.0176	0.0142	0.0016	0.0004
P40	121.750	520.273	54.326		0.0090	0.0202	0.0004	0.0002
P41A	121.754	520.242	51.851		0.0086	0.0196	0.0007	0.0003
P42A	127.481	528.338	52.077		0.0038	0.0101	0.0005	0.0003
P43	127.403	528.467	54.311		0.0077	0.0120	0.0003	0.0001

# MONITORING SURVEY RESULTS



## JOB DETAILS

Survey No 60  
 Job Name  
 Survey Date 01/12/2017  
 Survey By David Regan

## LIMITS (METRES)

Horizontal 0.0150  
 Vertical 0.0150

## SETUP ACCURACY (METRES)

Plan / Height <0.001 m

## TRIGGER VALUE COMMENTS

**Horizontal** Horizontal limits have been exceeded, see results  
**Vertical** Vertical limits have been exceeded, see results

## NOTES:

P10 Blocked due to Scaffolding | P11 Blocked due to Scaffolding | P14 Blocked due to Scaffolding | P15 Blocked due to Scaffolding | P16 Blocked due to Scaffolding | P17 Blocked due to Scaffolding | P55 Missing | P57 Missing | P48 Blocked due to refuse skip | P52A Blocked due to refuse skip | P44 Blocked due to Scaffolding | P50 Blocked due to Temporary Building | P37 Blocked due to Scaffolding | P38 Blocked due to Scaffolding | P39 Blocked due to Scaffolding | P47 Blocked due to Building Materials on roof of portacabin

SURVEYED POSITIONS					DIFFERENCES BETWEEN READINGS			
POINT ID	EASTING	NORTHING	HEIGHT	COMMENT	BASE - HORIZONTAL	BASE - VERTICAL	PREVIOUS - HORIZONTAL	PREVIOUS - VERTICAL
P45	126.040	526.479	64.678		0.0202	0.0156	0.0003	0.0003
P46	132.257	535.471	54.372		0.0075	0.0059		
P49	135.359	539.008	54.333		0.0085	0.0031	0.0008	0.0003
P51A	140.407	530.320	54.611		0.0073	0.0044	0.0009	0.0001
P53	139.398	527.770	51.794		0.0055	0.0070	0.0016	0.0004
P54	139.617	528.507	54.552		0.0093	0.0059	0.0015	0.0002
P56	140.207	529.380	65.541		0.0158	0.0067	0.0020	0.0003
P58	134.601	521.375	54.723		0.0073	0.0121	0.0008	0.0001
P59	134.563	521.273	51.379		0.0076	0.0105	0.0013	0.0001
P60	129.643	514.282	51.802		0.0070	0.0144	0.0014	0.0001
P61	129.619	514.241	54.948		0.0103	0.0141	0.0021	0.0000
P62	129.689	514.385	61.948		0.0156	0.0149	0.0016	0.0009
P63	129.690	514.400	65.568		0.0184	0.0141	0.0037	0.0008
P64	118.926	504.195	52.224		0.0009	0.0081	0.0012	0.0007
P65	112.564	508.663	52.046		0.0024	0.0110	0.0006	0.0006