

# CRACK MONITORING RECORD - RELATIVE MOVEMENT



## JOB DETAILS:


Reference No: 2187  
 Job Name:  
 1st Survey: 04/01/2018  
 Latest Survey: 12/06/2019

## SURVEY DETAILS:

Surveyed By: Tom Ayre  
 Gauge Used: Von Haus SR44

Gauge	DATE / SURVEY NO										Location
	13/03/18	29/05/18	18/07/18	15/10/18	10/01/19	11/02/19	14/03/19	11/04/19	08/05/19	12/06/19	
G1	0.00	-0.39	0.22	0.22	-0.75	-0.95	-0.18	1.53	-0.11	0.15	Below extension window
G2	0.00	0.16	0.47	0.61	-2.16	0.39	-1.41	0.13	0.36	1.66	Rear window LHS - Vertical Gauge
G3	0.00	0.21	0.77	0.12	-2.34	0.46	-1.70	0.43	0.38	1.54	Rear window LHS - Horizontal Gauge
G4	0.00	0.20	1.01	-0.37	-2.10	-0.77	-0.04	0.10	0.15	1.57	Rear Window - Above

Movement Over Time



# CRACK MONITORING RECORD - READINGS



## JOB DETAILS:

Reference No: 2187  
 Job Name:  
 1st Survey 04/01/2018  
 Latest Survey 12/06/2019

## SURVEY DETAILS:

Surveyed By: Tom Ayre  
 Gauge Used: Von Haus SR44  
 Dimensions: Millimetres

Gauge	DATE / SURVEY NO										Location
	13/03/18	29/05/18	18/07/18	15/10/18	10/01/19	11/02/19	14/03/19	11/04/19	08/05/19	12/06/19	
G1	2	3	4	5	6	7	8	9	10	11	Below extension window
G2	50.78	50.39	50.61	50.83	50.08	49.13	48.95	50.48	50.37	50.52	Rear window LHS - Vertical Gauge
G3	51.77	51.93	52.40	53.01	50.85	51.24	49.83	49.96	50.32	51.97	Rear window LHS - Horizontal Gauge
G4	51.57	51.78	52.55	52.67	50.34	50.80	49.10	49.53	49.92	51.45	Rear Window - Above
	50.20	50.40	51.41	51.04	48.94	48.17	48.13	48.23	48.38	49.95	



# Monitoring Setup Report

Wednesday, 17 April 2019

**Prepared by:** Chris Horton, Director

**Checked & approved by:** Tom Ayre, Director

**Proposal date revised:** -



THS Concepts LTD,  
92 Bellhouse Lane, Leigh-on-Sea, Essex, SS9 4PQ.  
Telephone: 0208 935 5160  
Website: [www.ths-concepts.co.uk](http://www.ths-concepts.co.uk)

This document has been prepared by THS Concepts Ltd. for the sole use of our client (the "Client") and in accordance with generally accepted monitoring surveying principles. Any information provided by third parties and referred to herein has not been checked or verified by THS Concepts Ltd, unless otherwise expressly stated in the document. No third party may rely upon this document without the prior and express written agreement of THS Concepts Ltd. This document is for the purposes of suggestion and must be agreed upon by a Structural Engineer or Party Wall Surveyor commissioned for the project. THS Concepts Ltd cannot be held liable for structural faults or damage, injury, death or any consequence of building movement due to construction works. It is the duty of THS Concepts to survey and report any displacement only. Agreement/confirmation of procedures as set out within this proposal are to be approved by a Structural Engineer or Party Wall Surveyor according to their own recommendations based on specific credentials and working knowledge. THS Concepts have no official accreditation and therefore cannot provide advice on Structural Engineering concerns.